




Sealing tape for rectangular ventilation ducts



R-FOLL sp. z o.o.

📍 32-010 Łuczyce, ul. Dworska 16


✉ **phone:** 12 346 42 96

☎ **e-mail:** biuro@rfoll.pl

www.rfoll.pl

R-FOLL presents a self-adhesive polyethylene tape of closed-pore structure for sealing joints between ventilation ducts and fittings with rectangular cross-sections.

Sealing tape used in a rectangular ventilation duct



Installation procedure:

- Clean dust and other contaminants from the duct surface where the tape is to be applied.
- Choose the appropriate tape width according to the rectangular ventilation duct.
- Apply the sealing tape peripherally at the joint with another duct/fitting.

NOTE! Tape installation at a temperature above +5°C

Application:

The tape seals contact points between rectangular ventilation ducts and fittings.

It effectively damps vibrations resulting from high wind loads.

Foam advantages:

- Seals joints of rectangular ventilation ducts
- Smooths away unevenness
- Damps vibrations
- Resistant to:
 - ageing
 - chemical impacts
 - reactions with organic substances
- Thermal resistance: (-40°C) do (+ 90°C)
- Easy and quick installation, place of application remains clean due to the lack of a paper interlayer.



Technical data

Standard size	10, 15, 20 mm
Standard lengths	10 , 15, 20 running metres (depending on tape thickness)
Hot melt glue	33-35 g/m ²
Foam density	30 kg /m ³
Total tape thickness	4, 5, 6, 7 mm +/- 8%
Thermal resistance	(-40) (+90) °C
Tensile strength	min 1,4 N/cm
Strip width tolerance	max } 1,5 mm
Strip length tolerance	max - 2%

R-FOLL sp. z o.o.

 32-010 Łuczyce, ul. Dworska 16

 **phone:** +48 12 346 42 96

 **e-mail:** biuro@rfoll.pl